

TOSHA
MOST CITED for Public Sector
January 2024 – December 2024



TOTAL Number of Violations for calendar year 1,078

Rank	Standard	Section Title	Violations	Description
1	1910.157(c)(1)	Portable Fire Extinguishers	78	Portable fire extinguishers were not provided, mounted, located, or identified
2	1910.303(b)(2)	Electrical Installation and Use	69	Listed or labeled equipment was not installed and used in accordance with any instructions included in the listing or labeling
3	1910.1200(f)(6)(ii)	Hazard Communication Workplace Labeling	58	In house chemical containers did not have identity of chemical & words, pictures, symbols, or hazard statements
4	1910.305(g)(1)(iv)(A)	Electrical Flexible Cords and Cables	51	Flexible cords were being used as a substitute for the fixed wiring of a structure
5	1910.305(b)(2)(i)	Electrical Covers and Canopies	38	Pull boxes, junction boxes, electrical outlets and fittings not provided adequate covers Flexible cord pendants passing through holes in covers of outlet boxes were not protected from damage
6	1910.305(b)(1)(ii)	Electrical Cabinets, Boxes, and Fittings	36	Unused openings in cabinets, boxes and fittings not effectively closed
7	1910.303(f)(2)	Electrical Disconnecting Means and Circuits	32	Each service, feeder, and branch circuit, at its disconnecting means or overcurrent device, not legibly marked to indicate its purpose
8	1910.37(b)(1)	Exit Routes and Emergency Planning	30	Exit routes not adequately lighted so employees with normal vision can see along the exit route
9	1910.304(g)(5)	Electrical Wiring Design and Protection	30	Path to ground from circuits, equipment and enclosures was not permanent, continuous and effective
10	1910.215(b)(9)	Abrasive Wheel Machinery	27	Tongue guards on bench grinders were missing or were not set to within 1/4 inch of the abrasive wheel

Rank	Standard	Section Title	Violations	Description
11	1910.1200(e)(1)	Hazard Communication Written Program	27	Lack of Hazard Communication Written Program
12	TDLWD Rule 0800-01-09-.07	Tennessee Right to Know Law Annual Refresher Training	27	Employees exposed to chemicals not provided annual refresher training and information
13	1910.303(g)(1)(ii)	Electrical 600 Volts Nominal or Less	24	Working space about electrical equipment was used for storage Working space in passageway or general open space was not suitably guarded when live parts exposed for inspection or servicing
14	1910.157(e)(2)	Portable Fire Extinguishers	21	Portable fire extinguishers were not visually inspected monthly
15	1910.147(c)(1)	Lockout / Tagout Energy Control Program	17	No LOTO program established for employees performing servicing or maintenance on machinery or equipment
16	1910.305(g)(2)(iii)	Flexible Cords and Cables	16	Effective strain relief between conductors and terminal screws or joints was not provided
17	1910.1030(c)(1)(i)	Bloodborne Pathogens Exposure Control	16	No written exposure control plan in place to eliminate or minimize employee exposures
18	1910.1030(c)(1)(iv)	Bloodborne Pathogens Exposure Control	16	No documented annual review of written exposure control plan, administrative, and engineering controls.
19	1910.215(a)(4)	Abrasive Wheel Machinery	15	Work rests on bench grinders were missing or were not set to within 1/8 inch of the abrasive wheel
20	1910.304(b)(4)	Electrical Outlet Devices	15	Outlet devices had an ampere rating less than the load being served